

Des Moines County Public Health

522 North Third Street • Burlington, Iowa 52601
Phone 319-753-8290 or Fax 319-753-8703

07/27/21

RE: Time of Transfer

Jeff Jennison
11014 Memorial Park Rd
Burlington, IA 52601

Dear Homeowner

This letter is being sent to inform you that upon completion of the time of transfer inspection done on 07/20/2021 for your property listed above, the septic system on that property does not pass inspection. A septic permit will need to be purchased from my office and a new primary and secondary system will need to be installed. A copy of this report along with this letter will be retained in our office.

A septic permit is enclosed with this letter.

Iowa Administrative Code 567-69.1 (3) "b". Discharge restrictions- It is prohibited to discharge any wastewater from private disposal systems (except as permitted) to any ditch, stream, pond, lake, natural or artificial waterway, county drain tile, surface water drain tile, or land drain tile, to the underground water, or to the surface of the ground. Under no conditions shall effluent from private sewage disposal systems be discharged to any abandoned well, agricultural drainage well or sinkhole. It is also required by code to have both a primary (septic tank) and a secondary (subsurface soil absorption, sand filter, or other approved secondary treatment) treatment system to ensure proper treatment before it is discharged.

For more information about septic systems, you can visit www.epa.gov/septicmart. If you have any questions, feel free to contact me at one of the number above or by email at glemkeruss2@gmail.com



Greg Lemke
Des Moines County Environmental Health Specialist - Sanitarian