

Water Sample Collection Information Form			Do not use this form for Public Water Compliance Samples		
Collection Date (MM/DD/YY) <u>1 / 4 / 21</u>		Time: <u>1:00</u> AM/PM <u>PM</u>	Collected By		License # (pump installer/well driller)
Owners Name <u>Amos & Lydia Bantager</u>			Owners Telephone Number () <u>No Phone Available</u>		
Owners Street Address <u>21786 Hurlbut Rd</u>			Well Address (Street or Legal Description)		
City, State, Zip Code <u>Gays Mills, WI 54631</u>			Town or City		County
Mail Results To:	Name <u>Steffes Group, Attn: Chris Richard</u>		Email Address (for electronic results) <u>terry.hoenig@steffesgroup.com</u>		
	Address <u>2245 E. Bluegrass Rd</u>		Test(s) Requested Bacteriological (100 mLs) <input checked="" type="checkbox"/> Nitrate (10 mLs) <input checked="" type="checkbox"/> Arsenic (100 mLs) <input checked="" type="checkbox"/> Other <input type="checkbox"/> (pd)		
	City State Zip Code <u>Mt. Pleasant, IA 52641</u>				
Sampler Remarks, if needed: <u>Terry's cell 319-470-7120</u> Private Sample Information Only			LABORATORY USE ONLY		
Reason for Test: <input type="checkbox"/> Annual Test <input checked="" type="checkbox"/> Real Estate <input type="checkbox"/> Taste/Odor <input type="checkbox"/> Previous Unsafe <input type="checkbox"/> Other			Bacteriological Approved Method <input checked="" type="checkbox"/> MMO-MUG (Colisure) <input type="checkbox"/> Membrane Filter <input type="checkbox"/> Presence/Absence <input type="checkbox"/> Other		
Sample Location: <input type="checkbox"/> Bath. Tap <input type="checkbox"/> Pressure Tnk. Tap <input checked="" type="checkbox"/> Kitchen Tap <input type="checkbox"/> Milk house <input type="checkbox"/> Other			Nitrate Approved Method 4500-NO3, SM 20th ed.		
Is Chlorine Present? Yes <input type="checkbox"/> No <input type="checkbox"/> Does the well serve the public? Yes <input type="checkbox"/> No <input type="checkbox"/> Public #:			SAMPLE REJECTION:		
STOP: If this is pump work please use a Pump Work Form! *Results are Required to be submitted to DNR Reason for Test: <input type="checkbox"/> *Pump Work <input type="checkbox"/> *New Well Well Construction Information <input type="checkbox"/> Drilled <input type="checkbox"/> Driven Point <input type="checkbox"/> Jetted <input type="checkbox"/> Dug <input type="checkbox"/> Other:			<input type="checkbox"/> Old <input type="checkbox"/> Chlorine Present-CL <input type="checkbox"/> Overgrown <input type="checkbox"/> Frozen-FR <input type="checkbox"/> Turbidity <input type="checkbox"/> Shipping Problem-SP		
			LABORATORY RESULTS:		
			Bacteriological Interpretation: <input checked="" type="checkbox"/> SAFE (Coliform Absent) <input type="checkbox"/> UNSAFE (Coliform Present) and: <input type="checkbox"/> Fecal/E. Coli Present <input type="checkbox"/> Fecal/E. Coli Absent		
Driller (If new Well): Lab Name: <u>LV Laboratories LLC</u> Lab Cert. # <u>105-443</u> Les Vondra 1015 S. Madison St Lancaster, WI. 53813 (608)723-4096 Email: <u>lesv@chorus.net</u>			Arsenic: _____ ug/L Wisconsin Department of Health Services (DHS) recommends that you stop using your water for drinking or food preparation if Arsenic level is greater than 10 ug/L (ppb)		
Amount Paid: <u>\$80.00</u> <input type="checkbox"/> Cash <input type="checkbox"/> Check <input checked="" type="checkbox"/> C.C. Date Paid: <u>1/4/22</u> Check No. _____ Staff Initials: <u>lv</u>			Nitrate: <u>1.68</u> mg/L as N Department of Natural Resources state that water is considered unsafe for infants under 1 year of age and pregnant women when nitrate level is greater than 10 mg/L (ppm)		
			Other: _____ : _____ mg/L or ug/L		
			Date/Time Received: <u>1/5/22</u> Bacteriological Nitrate Sample No. <u>F4013</u> Arsenic Sample No. _____ Date Reported <u>1/6/22</u> Date Received by DNR		
Sampling Disclaimer					
LV Laboratories, LLC reserves the right to reject any sample that is received non-compliant. All sample(s) must be received within 48 hours from the time the sample is collected. For additional samples rejections, see above. Sampler will be notified of sample rejection. If sampler requests testing to be done upon notification of sample rejection, LV Laboratories, LLC agrees to accept the sample(s) for testing and will qualify the results by dating and initialing below. LV Labs will keep copies for five years before disposal. "Sample not preserved with acid upon collection. Results cannot be used for SDWA compliance but are acceptable for NR 812 compliance" LV Laboratories, LLC _____ Date: _____					

Water Sample Collection Information Form

Do not use this form for Public Water Compliance Samples

Collection Date (MM/DD/YY) 1 / 4 / 2022	Time: 1:00 AM/PM	Collected By	License # (pump installer/well driller)
---	-------------------------	--------------	---

Owners Name Amos & Lydia Bontrager	Owners Telephone Number () No Phone Available
Owners Street Address 21786 Hurlbut Rd	Well Address (Street or Legal Description)

City, State, Zip Code Greys Mills, WI 54631	Town or City	County
---	--------------	--------

Mail Results To:	Name Steffes Group, Attn: Chris Richard	Email Address (for electronic results) terry.hoenig@steffesgroup.com
	Address 2245 E. Bluegrass Rd	
	City State Zip Code Mt Pleasant, IA 52641	

Sampler Remarks, if needed:
Terry's cell 319-470-7120

Private Sample Information Only

Reason for Test:

<input type="checkbox"/> Annual Test	<input checked="" type="checkbox"/> Real Estate
<input type="checkbox"/> Taste/Odor	<input type="checkbox"/> Previous Unsafe
<input type="checkbox"/> Other	

Sample Location:

<input type="checkbox"/> Bath Tap	<input type="checkbox"/> Pressure Trk. Tap
<input checked="" type="checkbox"/> Kitchen Tap	<input type="checkbox"/> Milk house
<input type="checkbox"/> Other	

Is Chlorine Present? Yes ☐ No ☐

Does the well serve the public? Yes ☐ No ☐

Public #:

STOP: If this is pump work please use a Pump Work Form!

*Results are Required to be submitted to DNR

Reason for Test:

<input type="checkbox"/> *Pump Work	<input type="checkbox"/> *New Well
-------------------------------------	------------------------------------

Well Construction Information

<input type="checkbox"/> Drilled	<input type="checkbox"/> Driven Point
<input type="checkbox"/> Jetted	<input type="checkbox"/> Dug
<input type="checkbox"/> Other:	

Driller (If new Well):

Lab Name: LV Laboratories LLC	Lab Cert. # 105-443
Les Vondra 1015 S. Madison St Lancaster, WI. 53813 (608)723-4096 Email: lesv@chorus.net	

Amount Paid: **\$80.00** ☐ Cash ☐ Check ☒ C.C.

Date Paid: **1/4/22** Check No. _____

Staff Initials: **lv**

Test(s) Requested

Bacteriological (100 mLs) <input checked="" type="checkbox"/>	Nitrate (10 mLs) <input checked="" type="checkbox"/>
Arsenic (100 mLs) <input checked="" type="checkbox"/>	Other <input type="checkbox"/>

(Pd)

LABORATORY USE ONLY

Bacteriological Approved Method	Nitrate Approved Method
<input type="checkbox"/> MMO-MUG (Colisure) <input type="checkbox"/> Membrane Filter <input type="checkbox"/> Presence/Absence <input type="checkbox"/> Other	4500-NO3, SM 20th ed.

SAMPLE REJECTION:

<input type="checkbox"/> Old	<input type="checkbox"/> Chlorine Present-CL
<input type="checkbox"/> Overgrown	<input type="checkbox"/> Frozen-FR
<input type="checkbox"/> Turbidity	<input type="checkbox"/> Shipping Problem-SP

LABORATORY RESULTS:

Bacteriological Interpretation:

☐ **SAFE** (Coliform Absent)

☐ **UNSAFE** (Coliform Present) and:

<input type="checkbox"/> Fecal/E. Coli Present
<input type="checkbox"/> Fecal/E. Coli Absent

Arsenic: **1.2** ug/L

Wisconsin Department of Health Services (DHS) recommends that you stop using your water for drinking or food preparation if Arsenic level is greater than 10 ug/L (ppb)

Nitrate: _____ mg/L as N

Department of Natural Resources state that water is considered unsafe for infants under 1 year of age and pregnant women when nitrate level is greater than 10 mg/L (ppm)

Other: _____ mg/L or ug/L

Date/Time Received: **1-5-22** **1/5/22 PM**

Bacteriological Nitrate Sample No.	Arsenic Sample No.
	ATTACHED PIA

Date Reported: **1/7/22**

Date Received by DNR: _____

Sampling Disclaimer

LV Laboratories, LLC reserves the right to reject any sample that is received non-compliant. All sample(s) must be received within 48 hours from the time the sample is collected. For additional samples rejections, see above. Sampler will be notified of sample rejection. If sampler requests testing to be done upon notification of sample rejection, LV Laboratories, LLC agrees to accept the sample(s) for testing and will qualify the results by dating and initialing below.

LV Labs will keep copies for five years before disposal.

"Sample not preserved with acid upon collection. Results cannot be used for SDWA compliance but are acceptable for NR 812 compliance"

LV Laboratories, LLC Date: _____



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

LV LABS WATER
1001 S MADISON STREET
LANCASTER, WI 53813

Home Owner P1A BANTRAGER, AMOS & L
Well ID/Address
Well City
Sample Location KITCHEN TAP
Lab # 582970
Collected By/Date 1/4/2022

Report Date 07-Jan-22

Analyte	Result	Units	LOD	LOQ	Dil	Dig Date	Run Date	Mthd	Analyst	QC Code
Inorganic Metals										
Arsenic, Total	1.2	ug/l	0.8	2.7	1		1/6/2022	3113B	NMP	1
(as total As) Elevated arsenic levels are believed to cause skin cancer, and blood and nervous system disorders. The EPA and the WI DNR consider levels above 10 ug/L (parts per billion) in drinking water harmful.										
LOD Limit of Detection			None Detected = Result was less than the LOD				LOQ Limit of Quantitation			

Code	Comment
1	All laboratory QC requirements were met for this sample.

Laboratory Director

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# WI 00063

WI Dept of Ag Lab ID # 152673-D3

Page 1 of 1